1171301 Rev 1.0



HIGH-LEVEL ALARM Datasheet

Description

The high-level alarm operates from a switched input, such as a float switch or pressure switch. The alarm can be activated either by a closed circuit switched input or an open circuit switched input.

Once activated, the alarm provides a visual and audio indicator. There is an option to connect an external beacon or other circuitry via the auxiliary output and/or the volt free relay output.

A mute button allows the operator silence the audio alarm of the unit without affecting the visual, auxiliary output or volt free relay output of the alarm.

A test button conveniently allows the operator to check the alarm functions without the need of triggering the input to the alarm.

Power to the alarm is indicated via a blue constant light, allowing easy operational inspection of the unit.

Typical uses for this alarm are high or low-level warnings in water treatment tanks.



Specification

		Rating
Enclosure		
	IP rating Dimensions Weight	IP65 rated 230x120x100mm 0.7kg
Supply Voltage		
	Minimum Maximum	110Vac [50/60Hz] 240Vac [50/60Hz]
Fusing		250mA [Internal]
Switched Input		
	Max cable length Switched voltage Max switched current	200m 5Vdc 10mA
Audio Output		
	Max sound level	105dB
Visual Alarm Output		Red flashing LED
Output Relay		
	Relay topology Max current Max Voltage	SPDT [COM/NO/NC] 10A @250Vac 250Vac
Auxiliary Output		
	Voltage Max Current	12Vdc 250mA [3W]
Terminal Capacity		0.2-4mm ² [tool free wire fitting]
Ambient Temperature		-10°C to +55°C

Key Features

- Alarm LED indicator
- Alarm audio buzzer
- Alarm audio mute button
- Alarm test button
- Power LED indicator
- IP65 rated enclosure
- Auxiliary alarm output for accessories such as a beacon or siren

- Volt free relay contact output SPDT
- Easily upgradable GSM module port
- Configurable for ACTIVE open or ACTIVE closed alarm input
- Easy installation no tool required WAGO wiring terminals

Contact

ADDRESS: Drainstore TEL: +44 (0) 1773 767611 Unit 5 Delves Road


Heanor Gate Industrial Park
Heanor
DE75 7SJ UK

EMAIL: sales@drainstore.com
WEBSITE: www.drainstore.com


Designed & Manufactured in the UK

1171301 Rev 1.0

Internal Features



Typical Installation



Float Switch Operation

Alarm ACTIVE Input Closed Circuit Alarm ACTIVE See [Float Switch Operation]

Alarm Active CLOSED Circuit Option

INSTALLATION WARNINGS

- When the cover of the product is removed, ensure the supply is isolated.
- Take extra care when connecting stranded cables into the connectors. Avoid lengthy uninsulated cable and ensure there are no loose cable strands
- Do not install this product where the audio alert from the alarm will be impeded.
 Please note the environment the product is situated will affect the audio & visual alert.